

Measurements °C


Sp1	15.8
Sp2	0.9
Sp3	0.7
Sp4	11.7

Parameters

Emissivity	0.95
Ref. temp.	20 °C

Shows cold air entering house.

3/22/2014 12:40:57 AM



FLIR0107 - Copy.jpg

FLIR E6

63911439

3/22/2014 12:40:57 AM



FLIR0107 - Copy.jpg

FLIR E6

63911439